

Laboratory Transformer Oil Testing Laboratory, Steag Energy Services (I) Pvt. Ltd,
A-29, Sector-16, Noida, Uttar Pradesh

Accreditation Standard ISO/IEC 17025: 2005

Discipline Electrical Testing **Issue Date** 11.09.2015

Certificate Number T-2623 **Valid Until** 10.09.2017

Last Amended on - **Page** 1 of 1

S.No.	Product / Material of Test	Specific Test Performed	Test Method Specification against which tests are performed	Range of Testing / Limits of Detection
I. INSULATING MATERIALS & INSULATORS				
1.	Transformer Oil	Dissolved Gas Analysis	IS 10593: 2006, IS 9434: 1992	H ₂ ≤ 1000 µl/l CO ≤ 5000 µl/l CO ₂ ≤ 5000 µl/l CH ₄ ≤ 1000 µl/l C ₂ H ₆ ≤ 1000 µl/l C ₂ H ₄ ≤ 1000 µl/l C ₂ H ₂ ≤ 1000 µl/l
		Electric Strength	IS 6792: 1992	5 kV to 100 kV
		Flash Point	IS 1448 (Part 21): 2012	50°C to 200 °C
		Water Content	IS 13567: 1992	1 mg/kg to 1000 mg/kg
		Density	IS 1448 (Part 16): 2014	0.800 g/cm ³ to 0.900 g/cm ³
		Neutralization Value	IS 1448 (Part 2): 2007	(0.02 mg KOH to 5 mg KOH)/g
		Dielectric Dissipation Factor(Tanδ)at 90°C	IS 6262: 1971	Max 1.0
		Resistivity	IS 6103: 1971	Min 0.1x10 ¹²
		Appearance	IS 1866: 2000 Clause. 7.1, IS 335: 1993	Qualitative (Clear, free from sediment & suspended matter)

~~-X-X-X-X-X-X-X-X-X-X-X-X-~~